Energy Management Workshop Kananaksis 2007

**Eco-Efficiency Program** 

Environment

Canada









### Eco-Efficiency Program (Energy and Environment)

Components
 Integrated Plant Audits
 Benchmarking
 New Technology Demonstrations









### Eco-Efficiency Program (Energy and Environment)

# Key Findings Energy Management is good business Economic benefits to industry Environmental benefits for all









### Integrated Plant Audit<sup>™</sup>

"A concurrent plant examination by a multidisciplinary team of leading industry experts, to seek out economic and environmental improvements."

## The whole is greater than the sum of the parts





Environment

Canada


















Areas of Expertise

□Gas treating Dehydration Refrigeration Compression, Turbines and Pumps **Sulphur Recovery, Incineration** Electrical Combustion, Boilers, Utilities **Fugitive Emissions** 





Canada

Environment Environnement Canada























### **Bulk DEA Unit**

#### **Ben Spooner**

Amine Experts Inc.





nment Environnement Canada





## **Bulk DEA Systems**

### HP System

Single absorber operated at 590 psig to <4 ppm spec</p>

### MP System

Single absorber operated at 235 psig to <10 ppm spec</p>

### LP System

Single absorber operated at 125 psig to <10 ppm spec</p>









### Bulk DEA Systems

Rich amine from all absorbers goes to common flash and then sent to a single regenerator

Goal of audit is to optimize units so that energy costs are at a minimum and performance of absorbers and exchangers is more consistent









## **Operating Data**

	HP FEED	MP FEED	LP FEED
H <sub>2</sub> S	16.6921	29.9894	6.1281
CO <sub>2</sub>	5.2833	6.4650	0.4348
COS	0.0030	0.0060	0.0025

□current HP flow is 61 MMSCFD

original design flow to the HP absorber was 150 MMSCFD

- Iooking at a production decline curve of 14% per year
- equipment turndown issues at current and proposed rates
- In-plant and third-party audits had already been undertaken - plant expected minimal energy savings from audit









### Plant Assessment

- Current performance corresponds to a rich loading of 0.532 mol/mol - room for optimization??
- Energy optimization in amine units is primarily achieved by a reduction in circulation rates









## Recommendations for Optimization

 Combination of circulation rate reduction and solution strength increase (with an understanding of allowable rich solution loadings) is the basis for the audit team's recommendations for new operating parameters









## **Optimization Steps**

Increase in amine strength from 28.5 wt% to 32 wt%
12% reduction in circulation rate
leads to an expected reduction in steam of 18 600 lb/hr
Further 7% reduction in circulation rate possible with increase in rich loading to 0.57 mol/mol (case sensitive)
Expected additional steam savings of 8 700 lb/hr for a total savings of 27 300 lb/hr









## **Result of Changes**

- No equipment changes; no new equipment
- After making suggested circulation rate reductions and strength increase, the plant reported the following

### improvements

- Steam reduction from 126 000 to 111 000 lb/hr estimated savings of >\$500 000/yr
- □ Treated gas H<sub>2</sub>S specification consistently lower than historical






Environment









### **Two Technologies**

Neil Franklin, P.Eng.

- Single Objective

Tartan Engineering Ltd.









## What Makes This Case Study Interesting?

Multiple Technologies

Combining technologies for a single result

Potential for Synergies

Energy savings through unit integration

Trade-off of Different Energy Forms

Environment

Energy consumption, high and low unit energy costs









## Situation

LPG recovery by

Propane Refrigeration and Lean Oil Absorption

Typically use either, rarely use both

- Propane condensing by two technologies
- Two forms of energy use
  - □ 1300 hp (Refrigeration) + 37 MMBTU/hr (Absorber)
  - □ \$3 million/year





Canada





## Audit Findings

- Plant running at 1/3 of design feed
  - Equipment oversized
- Opportunities to improve refrigeration Coefficient of Performance
  - □ Minimize compressor discharge in winter
  - Add economizer
- Poor efficiency in Lean Oil Absorber
  - Lean Oil composition too vague
  - □ Tray type? Tray damage?
  - Poor gas/liquid distribution?





Environment Environnement Canada Canada





## **Opportunities**

- Optimize individual units and combined operation of Refrigeration Unit & Lean Oil Absorber
  - Lower Chiller temperatures in Refrigeration Unit
  - Reduce lean oil circulation rates
- Achieve overall energy savings of \$1 million/year (33%)
  - □ Use electrical energy more effectively to save fuel use
  - □ 1/3 of savings through unit integration synergy
- Small capital investment
  - Economizer
  - Absorber internal/packing





Environment Environnement Canada Canada





### **Follow-Up Actions**

Confirm the opportunities

Computer simulation to confirm current and predicted operation

Engineering design of required modifications


Update operating procedures to reflect new situation














### **SRU** Incinerator

### Jamie Swallow

Sulphur Experts Inc.









### **Tail Gas Incineration**

- Sulphur Recovery Efficiency higher than licensed value (98.7 vs. 98.0)
- Still room to improve recovery efficiency (>99%)
- Considerable room to reduce fuel gas consumption by Tail Gas Incinerator





Environment





### Sulphur Recovery Unit Findings

- Sulphur Recovery performance impacted by COS and CS<sub>2</sub> losses
- Attributed to partial deactivation of catalyst in first stage









### **Tail Gas Incineration Findings**

Attainment of Total Reduced Sulphur destruction requires high excess oxygen

Stack top temperature is much higher than current sulphur inlet loading requires

One third of the energy available in the tail gas stream is not being utilized in the incinerator





Environment





## **Tail Gas Incineration Analysis**

- Incinerator performance is constrained by Total Reduced
   Sulphur destruction despite high oxygen level and high
   operating temperatures
- Lower Stack Top Temperature will not result in ground level SO<sub>2</sub> excedences
- Performance is indicative of poor mixing of the tail gas within the incinerator





Environment





### **Recommendations - SRU**

Replace catalyst in first converter using titania-based technology to assist COS and CS<sub>2</sub> hydrolysis









## Recommendations - Tail Gas Incinerator

Replace existing natural draft burners with a highintensity forced draft burner

This will:

□Improve mixing

Allow lower excess oxygen

Environment

Utilize energy from Tail Gas stream









## Recommendations - Tail Gas Incinerator

Apply for a tiered license based upon sulphur inlet loading

This will:

Allow Stack Top Temperature to be reduced and more closely match Total Reduced Sulphur destruction required





Environment





### **Projected Energy Reductions**

Incinerator fuel gas can be reduced by 48% in total

This will be achieved by:

□ Improved mixing – 22%

 $\Box$ Lower excess O<sub>2</sub> - 9%

Lower Stack Top Temperature – 17%









### Economic and Environmental Impacts

Reduced Fuel Gas - \$1 million


Reduced CO<sub>2</sub> (GHG) - >8 million tonnes














#### **Steam Plant Optimization**

#### **Nev Hircock**

Process Consulting Ltd.









 At design a sulphur plant generated 50 MMBTU/hr exothermic steam at 250 psig and the amine plant utilized 40 MMBTU/hr at 50 psig
 Back pressure steam turbines generated 1000 hp and an excess steam condenser balanced out the 10 MMBTU/hr difference









- 30 years later, the sulphur plant now makes only 20 MMBTU/hr and the amine plant needs only 20 MMBTU/hr
- In order to keep the steam turbines running, they need 30 MMBTU/hr of steam from the auxiliary boiler
- The auxiliary boiler needs to be retired or replaced





Environment





This is a common problem faced by older
 sulphur recovery plants when the exothermic
 aspect of the sulphur plant is no longer sufficient
 to meet the steam turbine requirements










**ENERGY MANAGEMENT WORKSHOP 2007** 

#### **Amine Plant**













#### **Back-Pressure Turbine**



CETAC-WEST

## **Condensing Turbine**



PETROLEUM TECHNOLOGY ALLIANCE CANADA PTAC

**Methane to Markets** 

- When the plant was built, the steam turbines were a good choice since the sulphur plant produced steam at 250 psi but the amine plant only required steam at 50 psi
   Taking the pressure drop across a turbine
  - produces essentially free energy

Environment









#### Available Options:

Install a new auxiliary boiler and install an extra 30 MMBTU/hr of excess steam condenser.

- □ Install the new auxiliary boiler and over-circulate the amine by a factor of 2 to condense the excess steam.
- Scrap the steam turbine, install 1000 hp of electric motors and let the sulphur plant balance the amine plant steam requirements.










## **Steam Turbines**

Back pressure turbines are very inefficient (<15%) unless the exit steam is used for heat transfer.

Condensing turbine efficiency can be quite good (>35%)

...IF the steam pressure is very high and superheated and condensing pressure is very low.











## **Steam Case Options**

	Action:	Capital Cost \$k	Annual Operating Cost \$k	3 Year Combined Cost \$k
1	Add Auxiliary Boiler and Excess Steam Condenser	1500	1650	6450
2	Add Auxiliary Boiler and over circulate Amine	900	1860	6480
3	Remove Steam Turbines and install electric motors	60	390	1230

Assumptions:

Fuel @ \$6 per MMBTU Electricity @ 6c per kWh









## Conclusions

- When process conditions change, the original design may no longer be appropriate
- Continuing to operate "the way we always have" can be an expensive option
- The cost of fuel gas must be considered in evaluating alternatives





Environment







#### **Energy Management**

#### **Brian Tyers**

**Stantec Consulting** 









## Case Study

#### **Gas Plant Facility in Central Alberta**

Background

□ Fuel use cycling up

Electrical use steady

Production cycling down

Environment

Canada









**ENERGY MANAGEMENT WORKSHOP 2007** 

## Energy audit and conservation initiatives implemented Energy Reduction of 15%



No system established / installed to monitor and target the energy use relative to production









Set Up

- Energy Champion appointed Plant Lead Operator
- CUSUM introduced and steps performed:
  - □ Data collection (production, fuel gas, electricity)
  - □ Baseline selection
  - Correlations for predicting energy use variation
  - Estimate of difference in energy use
  - Cumulative summation of differences









#### Actions

Energy Champion Recorded readings daily (part of existing log reporting)  $\Box$  Looked for changes in direction (~10 minutes per day) Consulted with operating staff (part of daily meeting) Determined what caused the change Eliminated improper actions Replicated beneficial actions Communicated results






Environment





#### Savings by Quarter



## Summary

#### Significant economic savings

Identified energy savings were 9-20% (\$400 to \$900K) compared to baseline performance
 Cost to Implement - \$20,000 plus noted Lead

Operator time

#### Simple Payback: 1.2 to 2.6 weeks

Environment

Canada









#### Summary

#### Greater retention of savings

- Lack of M&T can erase energy management gains
- CUSUM can hold, **and extend**, those gains
- Greater ability to deal with 2 significant problems for Western Canadian operations
  - Changing throughput
  - Extremes of climate
- Need to periodically update baseline









### Summary

Change in operator view of energy management

#### Before

- Energy consumption is inevitable...
  - What can We do about it?

#### Now


- □ We can make a difference...
  - **We** can reduce our energy use.
- Selling concept to Field Operators











# **ENERGY MANAGEMENT WORKSHOP 2007 Case Study Fugitive Emission**

**Marline Smith** 

**Reduction Opportunities** 

Clearstone Engineering Ltd.









## Why Target Natural Gas Losses and Fugitive Emissions?

- Sensible means of reducing greenhouse gas (GHG) emissions in a transparent and verifiable manner
  - Cost-effective control opportunities based on value of saved gas
  - □ Typically low capital cost of controls
    - "Low hanging fruit"
  - High GHG intensity
    - Global warming potential CH<sub>4</sub> = 21.0 \* CO<sub>2</sub>
  - Measurement of baseline GHG emissions may become important for GHG trading programs





Environment Environnement Canada Canada





## **Facility Description**

#### Sour compressor facility

- continuously manned
- □ 1 turbine compressor
- □ 5 reciprocating compressors
- 2 dew point control trains
- 2 flare systems

#### Equipment components surveyed: 5 471









## **Emission Survey Findings**

- Fugitive emissions
  - 84 leakers identified, 25 cost-effective repairs
  - □ 3 largest leakers 3 170 x 10<sup>3</sup> m<sup>3</sup>/yr in losses
    - recip. start gas vent \$587 000/yr
    - packing case vent \$ 82 000/yr
    - packing case vent \$ 75 000/yr
  - **Total identified losses: 3 200 x 10<sup>3</sup> m<sup>3</sup>/yr**
  - Fugitive GHG emissions: 43 600 tonnes CO<sub>2</sub>E/yr









## **Emission Survey Findings**

#### Flared gas

Excessive flaring observed

blowdown valve partially open

Source eliminated during visit

Potential savings for site:

Environment

□ GHG emissions 43 500t CO<sub>2</sub>E/yr

Avoided natural gas losses \$ 755 000/yr

#### 99% of emissions avoidable at NO NET COST









#### **Recommendations & Deliverables**

#### Recommendations:

- Undertake cost-effect repair opportunities
- Install flow indicators on compressor vents early detection of leakage problems
- Install monitoring ports on flare system periodic checks for leakage into flare header

#### Deliverables:

- Ranked listing of identified control opportunities
- Cost-curve for reduction of natural gas losses
- Baseline emissions inventory









#### **Emission Reduction Opportunities: KEY FEATURES**

- Opportunities greatest at older and un-manned facilities
- □ Lack of reliable visible or audible indicators
- Emissions occur at elevated or difficult to access locations
- □ Lack of measurement data
- Typically 70-80% of fugitives are cost-effective to control (less than 1 year paybacks)

Most fugitive emissions result from fewer than 10 sources per site









#### In conclusion...

- Significant financially attractive opportunities to control natural gas emissions do exist
  - Can be overlooked or understated in absence of reliable measurement or estimation results
- Opportunities would not be quantified without an audit
- Fugitive emission reduction opportunities are worth pursuing from a GHG perspective
   High GHG intensity of CH<sub>4</sub>





Environment Environnement Canada Canada





## **Integrated Plant Audit**

Requires: Unit by unit expertise Multi-disciplinary approach Concurrent effort